

**City of Chelsea**  
**IFB 2016-170**  
**Netting Project at Carter Park**  
**Addendum #3**

**Notice to all prospective bidders**

**Addendum #3 released Thursday, April 28, 2016**

**The following changes have been made to the contract specifications:**

- a) 14'-0" min. excavation depth.
- b) 18" pole diameter.
- c) No concrete work needed.
- d) The revised plan drawing is attached.

Addendum #3 was prepared in consultation  
with: Dylan Cook, Chief Procurement Officer  
David Choi, Jacobs Engineering

***Bidders are reminded that the Bid Form must acknowledge receipt of any and all addendum.***

**The City reserves the right to reject any and all bids as determined to be in the best interest of the City and to waive minor informalities.**

